



REQUIREMENTS FOR COMMERCIAL VERTICAL PLATFORM LIFTS (ENCLOSED)

- **FLUSH SURFACE** on the lift running side(s)
- **ALL LANDING GATES AND DOORS** needs to be supported
- **RUNNING CLEARANCE** should be no more than 5/8" (see drawing)
- **DEDICATED lockable and fused disconnect(s)** See drawings for specific requirements
- **GFI OUTLET** (separate circuit from lift) located at the bottom landing within 10' of the mast
- **BLOCKING** at location shown on site specific drawing to support the loads indicated
- **ADEQUATE LIGHTING** at both landings (with emergency backup lighting) including above the hoistway
- **NO EXPOSED WOOD** in a fire rated hoistway
- **PIT** (if required) to be smooth and water tight and include a switched guarded pit light
- **FINISHING AROUND FIRE DOORS** to be completed after doors are installed (fire caulking if required)
- **Hoistway** must be plumb and true within 1/8 " over 25'

