



REQUIREMENTS FOR COMMERCIAL VERTICAL PLATFORM LIFTS (UNENCLOSED)

- **FLUSH SURFACE** on the lift running side
- **CONCRETE PAD** to support lift base
- **UPPER LANDING GATE OR DOOR** needs to be supported
- **RUNNING CLEARANCE** should be no more than 5/8"
- **15 AMP DEDICATED 120 VAC lockable and fused disconnect**
- **GFI OUTLET (separate circuit from lift) located at the bottom landing within 10' of the mast**
- **BLOCKING** at location shown on site specific drawing
- **ADEQUATE LIGHTING at both landings (with emergency backup lighting) - secondary ballast required above lift**

